

JOB

ADDRESS

OWNER

323 589-1697

NOTICE OF VIOLATION

The work performed is in violation of the Ordinance(s) indicated below:

☒ Building Code ☒ Plumbing Code
☐ Mechanical Code ☒ Electrical Code
☒ ~~HOE LOW EXTERIOR WALL~~ ☐ Zoning Code

HEATING SYSTEM IS NOT WORKING
DESCRIPTION: ELECTRICAL (OUTLETS)
KITCHEN NOT WORKING
BATHROOM PLUMBING FIXTURES
NEEDS REPAIRING, HOLE IN
WALL ABOVE SINK
BELOW KITCHEN SINK
MISSING SMOKE DETECTORS
MISSING RELEASE ON
BEDROOM WINDOW SECURITY
BARS IN CASE OF FIRE REPAIRING

☒ STOP ALL WORK
☒ Submit plans for the cited work within 10 days to the office listed above and apply for a plan check for the required permit(s).

☐ Obtain permit(s) within 10 days at the office listed above for the cited work.

☐ A referral has been made to the Enforcement Section of the Department of Regional Planning.

6-8-2001
DATE

INSPECTOR'S SIGNATURE

G. RODGERS